

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1129

Dated. 30-01-26

It is certified that an inspection team headed by Satya Sander Pati, (Microbiologist) (Name of Officers with designation) from DHH, Bhadrak (Name of Department/Office) inspected the Adani DAV Public School, At/PO-Kuamara, Via-Naikanidihi, Dist-Bhadrak, PIN-756164 on 27/01/26 (date of inspection) and found that the Adani DAV Public School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State /U.T. Govt.

The above is valid for a period of one year.

Signature with Seal.....

Sal
30/1/2026
ADPHO(DC)
BHADRAK

Name

Dr. Sangita Bal

Designation

ADPHO-DC, Bhadrak

Name & Address of the Office/Department:.....

o/o- CDM & PHO, Bhadrak

To

The Principal

Adani DAV Public School

At/Po-Kuamara, Via-Naikanidihi

Dist- Bhadrak, PIN-756164



OFFICE OF THE CHIEF DISTRICT MEDICAL & PUBLIC HEALTH OFFICER: BHADRAK
(PUBLIC HEALTH WING)

DISTRICT PUBLIC HEALTH LABORATORY

Phone No: 06784-250890 Email ID: dsubhadrak@gmail.com



Microbiological Testing of Water Sample (Culture)			
Block/CHC	AdaniDAV Public School, Kuamara, Bhadrak	District	Bhadrak
Date of Collection/Testing	27.1.2026	Date of Result	30.1.2026

Sl No.	Area of Collection*	H ₂ S test	Ortho Toluidine test	Most probable Number MPN Score (Culture)**	Remark
1	Tap water, Ground Floor	Negative	1.0	00	EXCELLENT
2	Tap water, 1 st Floor (I)	Negative	1.0	00	EXCELLENT
3	Tap water, 1 st Floor (II)	Negative	1.0	00	EXCELLENT
4	Tap water, 2 nd Floor	Negative	1.0	00	EXCELLENT

*The samples were collected by Microbiologist, DPHL, DHH, Bhadrak

**MPN score: (00: Excellent, 1-3: Satisfactory, 4-10: Suspicious, >10: Unsatisfactory)

S. Dal
30/1/2026
ADPHO (DC)
DPHL, Bhadrak
C. Dr. Sangita Dal.)
ADPHO (DC)
BHADRAK